



CODE	NAME
AP1	Main Board1
AP2	Main Board2
AP3	Main Board3
AP4	Main Board4
COMP	Compressor
EH3	Plate heat exchanger anti-freezing
EH4	Compressor band heater
EH5	Bottom band heater
EH6	expansion tank heater
EKV1	Electronic expansion valve coil1
EKV2	Electronic expansion valve coil2
HL1	Running indicating lamp
HL2	Error indicating lamp
HP	High pressure switch
KM1	Auxiliary electric heater 1 AC contactor
KM2	Auxiliary electric heater 2 AC contactor
L	Electrical Inductance
L1	Electrical Reactance
L2	Electrical Inductance 1
L3~L10	Magnetic ring
M1	DC motor
M2	Indoor unit pump
RT1	Plate heat exchanger water-out temp sensor
RT2	Plate heat exchanger water-in temp sensor
RT3	Auxiliary heater leaving water temp sensor
RT6	Remote room temp sensor1
RT7	Remote room temp sensor2
RT8	Pool water temp sensor
RT9	Pool water-in temp sensor
RT10	Pool water-out temp sensor
RT14	Defrosting temp sensor
RT15	Outdoor temp sensor
RT16	Discharged temp sensor
RT17	Suction temp sensor
SP1	High pressure sensor
SP2	Low pressure sensor
SP3	Enthalpy increasing pressure sensor
SW2	Swimming Pool waterflow switch
SW3	Indoor units waterflow switch
TC	Transformer
XT1	Terminal block (L, N, 1, 2)
XT2	Terminal block (1~20)
XT3	Terminal block (1~6)
XT4	Terminal block (21~42)
YV1	Increase Enthalpy solenoid valve
YV4	4-way valve coil

KRONE Kälte+Klima Vertriebs-GmbH

	bearbeitet:	geändert:
Name:	H.H.	
Datum:	12.09.2017	
Uhrzeit:		
HLR-10-K Kaltwassersatz		